

GEORGE WILLIAM RILEY
AND ASSOCIATES
1090 FERGUSON ROAD
SEBASTOPOL, CALIFORNIA 95472
TELEPHONE (707) 829-2683

OK
W. Riley 12-7-83

Dec. 5, 1983

Santa Rosa Building Dept.
100 Santa Rosa Ave.
Santa Rosa, Ca. 95402

RE: Masonic Center

Dear Sir:

The above referenced building's present classification is A-2.1 & B-2. We would like to reclassify the building to A-2.1. The following analysis shows that the building meets those requirements.

Area: 20,400 Sq. Ft.
Type: V-one hour - Sprinklered
Three sideyards of 60 ft or more - Increase basic area 100%
Table 5-C - Type A-2.1 allowable area = 10,500 sq ft.
Three sideyards = $10,500 \times 2 = 21,000$ is greater than 20,400. O.K.

The building was designed using "Importance Factor I=1.5".

Sincerely,

George W. Riley
George W. Riley Architect C-3348

DEPARTMENT OF
COMMUNITY DEVELOPMENT
THE PERMIT FOR THE WORK INDICATED
ON THESE PLANS IS APPROVED ON THE
BASIS THAT ALL WORK WILL COMPLY
WITH ALL REQUIREMENTS OF THE CITY
OF SANTA ROSA, WHETHER SHOWN ON
THESE PLANS OR NOT.

DIRECTOR